DENEY SERTİFİKASI

TEST CERTIFICATE

TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

Firma Unvanı *Company Name*	:	**YILDIZ ENTEGRE AĞAÇ SANAYİ VE TİCARET ANONİM ŞİRKETİ**
Firma Adresi *Company Address*	:	ARSLANBEY OSB MAH. 1. CAD. NO:13 /2 KARTEPE 41285-/KOCAELİ
Numunenin Tanımı *Sample Description*	:	8mm-18mm arası kalınlıkta FR MDF (FR MDF Thickness b/w:8mm-18mm)
Ticari Marka/Model *Commercial Brand/ Model*	:	YILDIZ TREND / -
Deneylerin Yapıldığı Tarih Aralığı *Date Interval of Tests*	:	30.05.2023 - 4.07.2023
Uygulanan Standard(lar) / Metot (lar) ve/veya Tebliğ/Yönetmelik *Applied Standard/Method and/or Notification / Regulations*	:	02/07/2020 - TS EN ISO 11925-2, 09/11/2020 - TS EN 13823, 16/12/2019 - TS EN 13501-1
Deney Raporları *Related Test Reports*	:	TSE / 04/07/2023 - 198444, TSE / 04/07/2023 - 198461, TSE / 04/07/2023 - 198468, TSE / 04/07/2023 - 198442, TSE / 04/07/2023 - 198446, TSE / 04/07/2023 - 198464
Özet Açıklama *Summary Explanation*	:	Firma tarafından gönderilen numune(ler) yukarıda atıf yapılan raporun(ların) verildiği laboratuvar(lar)da test edilmiş ve yukarıda atıf yapılan deney raporunda(larında) uygulanan ilgili standard(lar) / metot(lar) / tebliğ(ler) / yönetmelik(ler) maddesine(lerine) göre uygunluk bulunmuştur. *The sample(s) submitted by the company has been tested in laborator(y)(ies) where the above mentioned report(s) are given and found to comply with the relevant clause(s) of the applied standard (s) / method (s) / communique (s) / regulation (s) in test report(s) above mentioned*

TÜRK STANDARDLARI ENSTİTÜSÜ
tse.org.tr

Sonuç *(Result)*

Yangına Tepki Sınıfı : B-s2,d0

Reaction To Fire Class : B-s2,d0

e-imzalı/e-signed

SENCER GÜVEN

YAPI MALZEMELERİ YANGIN VE AKUSTİK LABORATUVAR MÜDÜRLÜĞÜ

DIRECTORATE OF CONSTRUCTION MATERIALS FIRE AND ACOUSTICS LABORATORY

Sertifika No : LAB17-DS/393 | Veriliş Tarihi : 04.05.2026 | Son Geçerlilik Tarihi : 04.05.2028

Certificate No | *Date of Issue* | *Date of Expiry*

Bu sertifika istek üzerine yukarıda atıf yapılan rapor(lar)a istinaden düzenlenmiş olup sadece deneyi yapılan numune için geçerlidir. Bu sertifika herhangi bir "Ürün Belgesi" veya "Uygunluk Belgesi" niteliğinde değildir. Bu sertifika TSE marka kullanım hakkı vermez, ayrıca partiyi temsil etmez. *This certificate was prepared upon request according to the mentioned test report(s) above and represents only tested sample(s). This certificate does not represent any "Product Certificate" or "Certificate of Conformity". This certificate does not give permission to use the brand of TSE, also does not represent the batch.*

https://evrakkontrol.tse.org.tr/SertifikaDogrulama.aspx?p=2rwvl8un adresinden belgenin doğruluğunu ve geçerliliğini sorgulayınız.
Please, question the authenticity and validity of the certificate from the given link **https://evrakkontrol.tse.org.tr/SertifikaDogrulama.aspx?p=2rwvl8un**

www.tse.org.tr